

Change Log			
1. Improved PV mppt tracking			
2. Added forced off grid mode			
3. Improved remote updating			
4. Added advanced mode display for the secondary inverters in parallel mode			
5. Moved some functions to maintenance menu			
6. Added CT limit value setting ffrom panel			
7. Added bat low standby setting from panel			
8. Added BMS id for Pylon similar CAN BMS protocol			
9.Deleted generator manual enable/diable			